



Village of Woodridge

Community Development Department – Five Plaza Drive – Woodridge, IL 60517-5014
(630)719-4750 – TTY (630)719-2497 – FAX (630)719-2900

WATER

- Minimum 1" diameter
- Type "K" copper or ductile iron
- Continuous line without splices
- No sweated joints on street side of meter
- All fittings must be flared; compression or Ford fittings on repairs only
- Valves must be full flow - gate or ball
- Installed 10'-0" from sewer or shelved 18" up and over
- Minimum burial depth 4'-0"
- Line must be pressurized for inspection
- Unused tap to main must be removed entirely and section repaired.

SEWER

- Through foundation wall - ductile or cast iron. If PVC is used it must pass through a metal sleeve two sizes larger & be protected with an expansion seal
- PVC must be SDR 26, 6" minimum diameter
- Cast iron - 4" minimum
- Minimum bed and cover of 4" CA-7 gravel
- Line must slope away from building
- Minimum burial depth 4'-0"
- Connection to main must be 6" diameter, minimum, and be made by a wye fitting with an angle of 30-45 degrees.
- Joints must be made by the following means: push-in gaskets, "no-shear" mission couplings.
- Clean-outs must be installed with sanitary tee
- Unused tap to main must be removed entirely and section must be replaced with no shear mission coupling.

NOTE:

- **Call for inspection after sewer & water installations are complete, water line is pressurized, and the sewer is properly bedded. Leave connections visible for inspection.**
- **Restoration of the R.O.W. is required within 2 weeks of the repair, weather permitting and is the responsibility of the contractor. A pre-pour inspection is required for public walk replacement. Walks to be backfilled with CA-7 gravel (Washed $\frac{3}{4}$ ", no fines) and be poured at a 4" thickness.**
- **Remember to protect the hole if it must be kept open overnight**
- **A clean-out shall be located within 5 feet of the building foundation, either on the inside or the outside of the building.**
- **Call for final inspection after all sidewalks have been replaced and the yard has been restored.**
- **Sewer and water excavations on private property shall be compacted, leveled and restored to natural grade within six (6) months of the date of the issuance of the permit. (Ord. 2006-17, 4-20-2006)**

FOR LOCATION OF UTILITIES CONTACT J.U.L.I.E AT 1-800-892-0123

Permit Fee: \$50.00