

Motion No.

BOARD MEETING AGENDA ITEM - HISTORY/COMMENTARY	
ITEM TITLE: Bid 2016-08 Underground Storage Tank Removal - 1 Plaza Drive	AGENDA DATE: 11/3/2016
ITEM REVIEW	
TO:	Mayor & Village Board
THROUGH:	Al Stonitsch, Village Administrator
FROM:	Chris Bethel, Director of Public Works
INITIATOR:	Chris Bethel, Director Public Works

ITEM HISTORY:

The Village's existing fueling station for municipal operations was originally constructed in approximately 1985 and while there are no known issues, a proactive decommissioning was planned for this year due to its age (original single walled fiberglass tanks with a manufacturer's estimated life of 25-30 years). The Village worked with the environmental engineering firm of Huff and Huff to complete soil boring and various tests of the area and no contamination or leaks were found in the area. Huff then assisted with the bid specifications for the tank removal, and will be completing the required State paperwork for the Village and monitoring the tank removal process. As the Woodridge Park District, Lisle Woodridge Fire District, and School District 68 currently utilize the facility they have been updated throughout the process so they can make alternative fueling arrangements for the future.

ITEM DISCUSSION:

Notice published in the Daily Herald on October 10, 2016 with a Bid Opening Date of October 24, 2016.

Number of Bids Received: 4

Public Works has reviewed the four (4) bids that were received in response to bid #2016-08, Underground Storage Tank Removal – 1 Plaza Drive. The base bid summary is as follows:

AQS Services	\$38,526.55*
<i>*amount was not totaled on the bid submittal</i>	
Integrated Environmental Solutions	\$47,780.00
Orvine Inc.	\$29,330.00
RW Collins Company	\$28,200.00

The low bid from RW Collins, Co. at \$28,200 was responsive to all bid requirements and the pricing is in line for a project with no known leaks. A municipal reference was positive and additionally, optional Huff and Huff has worked with RW Collins, Co. on similar projects in other locations and found them to be a competent contractor.

Additionally, optional unit pricing was received under the bid in anticipation of other potential work that may be needed under the project (additional backfill, disposal of fuel, trucking, etc.).

Motion No.

RW Collins pricing was reasonable and competitive with the other companies for all optional items as well.

Public Works recommends that the Village Board award bid 2016-08, Underground Storage Tank Removal – 1 Plaza Drive to RW Collins Co. in the amount of \$28,200. A total of \$425,000 was budgeted including \$100,000 for decommissioning (the budget was in the event a larger remediation project was required). The other \$325,000 was for construction of a new facility and was re-budgeted.

ACTION PROPOSED:

Approval of the Motion

ATTACHMENTS:

RW Collins Bid Submittal_102416 (PDF)

Motion No.

Bid 2016-08 Underground Storage Tank Removal - 1 Plaza Drive

DO NOT ENTER INFORMATION HERE - WILL NOT APPEAR IN ITEM.

PASSED this 3rd day of November, 2016.
RESULT: **ADOPTED BY CONSENT VOTE [5 TO 0]**
MOVER: Mike Krucek, Trustee
SECONDER: Gregory Abbott, Trustee
AYES: Blair, Martinez, Krucek, Page, Abbott
ABSENT: Pamela Beavers

APPROVED this 3rd day of November, 2016.

ATTEST:

Filed in the Office of the Village Clerk and published in pamphlet form by authority of the Mayor and Board of Trustees of the Village of Woodridge, DuPage, Will, and Cook Counties, Illinois, this 3rd day of November, 2016.